



Ref. Certif. No.

HU-003808

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Moulded Case Circuit Breaker
Name and address of the applicant	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Name and address of the manufacturer	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Name and address of the factory	Zhejiang Tengen Electric Co., Ltd. Sulv Industrial Area, Liushi Town, Yueqing City, 325604 Zhejiang, P.R. China
Ratings and principal characteristics	Ue: AC 220V/230V/240V (1P, 2P, 1P+N), AC 380V/400V/415V (2P, 3P, 3P+N, 4P); In: 63A, 80A, 100A, 125A; Over-current Trip Unit: Thermo-magnetic; Selectivity Category: A; Icu=Ics=6kA for 1); Icu=10kA and Ics=7.5kA for 2); 50/60Hz
Trademark (if any)	Tengen (Logo)
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) TGB1N-125 2) TGB1N-125H
Additional information (if necessary may also be reported on page 2)	Detailed information refer to test report CN22ER87 001.
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN22ER87 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2022-03-14

Signature: Wencai Zhang