



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200311007058

Product Household AC contactor

Applicant Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model TGCH1N-16, TGCH1N-20, TGCH1N-25

Technical data

Uimp:4kV; Ui:500V; Ith:25A;
Ue:AC250V(1P,2P),AC400V(3P,4P);
TGCH1N-16:Ie:16A(AC-7a),6A(AC-7b);
TGCH1N-20:Ie:20A(AC-7a),7A(AC-7b);
TGCH1N-25:Ie:25A(AC-7a),9A(AC-7b); AC-7a,AC-7b;
Us:AC24V,AC48V,AC110V,AC230V,50/60Hz; 1P,2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No.
C-14201-DC195134, the submitted sample(s) of the above item complies with:

EN 61095:2009

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

Valid from: Dec.30,2020

Valid until: Dec.30,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>