



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006736

Product

ATSE

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang Province,
P.R.China

Type/Model

TGQ1N-250L/3,TGQ1N-250M/3,TGQ1N-250L/4,TGQ1N-250M/4,
TGQ1N-320L/3,TGQ1N-320M/3,TGQ1N-320L/4,TGQ1N-320M/4;

Technical data

Uimp:8kV(main circuit),2.5kV(control circuit);Ui:800V(main
circuit),400V(control circuit);Ue:AC400V; Ith:320A;
TGQ1N-250L/3,TGQ1N-250M/3,TGQ1N-250L/4,TGQ1N-250M/4:Ie:1
60A,180A,200A,225A,250A;TGQ1N-320L/3,TGQ1N-320M/3,TGQ1N-
320L/4, TGQ1N-320M/4:Ie:250A,280A,300A,315A,320A;Utilization
category:AC-33B;Icm:73.5kA(Type L),105kA(Type M);Icn:35kA(Type
L),50kA(Type M); Class CB; Method of controlling: ATSE,RTSE; 3P,
4P

This is to certify that, on the basis of the tests undertaken as per Report No. (2019)FQIIDQCE-0186,
the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Mar.10,2020

Valid until: Mar.10,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>